

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0065:174

Page 1 of 1

CATEGORY: Heat Detectors

LISTEE: Faraday Inc., 805 S. Maumee Street, Tecumseh, MI 49286
Contact: Steve Blohm (517) 423-2111

DESIGN: Model 8812 electronic 135 °F fixed temperature heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 135 °F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fixed temperature heat detector for use with separately listed compatible fire alarm control units and Model 8853 base (CSFM Listing No. 7300-0065:158).

07-26-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager